

SPECIFICATION

Section 07 09 00 / 07 95 00

SEISMIC IBS Series

Preformed, Pre-Compressed, Self-Expanding, Sealant System with Silicone Pre-Coated Surface
Watertight, Energy-Efficient, Exterior and Interior Above Grade Wall Joints

PART 1 – GENERAL

1.01 Work Included

- A. The work shall consist of furnishing and installing waterproof expansion joints in accordance with the details shown on the plans and the requirements of the specifications. Preformed sealant shall be silicone pre-coated, preformed, pre-compressed, self-expanding, sealant system.
- B. Related Work
- Division 4 - Masonry
 - Division 7 - Thermal & Moisture Protection
 - Division 7 - Sealants, Caulking and Waterproofing

1.02 Submittals

- A. General – Submit the following according to Division 1 Specification Section.
- B. Standard Submittal Package – Submit typical expansion joint drawing(s) indicating pertinent dimensions, general construction, expansion joint opening dimensions and product information.
- C. Sample of material is required at time of submittal.
- D. All products must be certified by independent laboratory test report to exceed the requirements of curtain wall performance tests ASTM E330, E283-04, and E331. Product must meet or exceed hurricane-force wind loading with no deflection at both positive and negative pressures up to 4954 Pascals—equal to 200 mph winds (ASTM E330-02-procedure A).
- E. All products must be certified by independent laboratory test report to ASTM E90-09 and to meet or exceed an STC 52 in STC 56 wall and OITC 38 rating in an OITC 38 wall.
- F. All products must be certified by independent laboratory test report to be free in composition of any waxes or wax compounds using FTIR and DSC testing.
- G. All products shall be certified in writing to be: a) capable of withstanding 150°F (65°C) for 3 hours while compressed down to the minimum of movement capability dimension of the basis of design product (-50% of nominal material size) without evidence of any bleeding of impregnation medium from the material; and b) that the same material after the heat stability test and after first being cooled to room temperature will subsequently self-expand to the maximum of movement capability dimension of the basis-of-design product (+50% of nominal material size) within 24 hours at room temperature 68°F (20°C).

1.03 Product Delivery, Storage and Handling

- A. Deliver products to site in Manufacturer's original, intact, labeled containers. Handle and protect as necessary to prevent damage or deterioration during shipment, handling and storage. Store in accordance with manufacturer's installation instructions.

1.04 Basis of Design

- A. All joints shall be designed to meet the specified performance criteria of the project as manufactured by: Prospec Specialties Inc., Suite 400, 3601, Highway 7, Markham ON, L3R 0M3, Canada

www.prospecspecialties.com

- B. Alternate manufacturers must demonstrate that their products meet or exceed the design criteria and must submit certified performance test reports performed by nationally recognized independent laboratories as called for in section 1.02 Submittals. Submittal of alternates must be made three weeks prior to bid opening to allow proper evaluation time.

1.05 Quality Assurance

- A. The General Contractor will conduct a pre-construction meeting with all parties and trades involved in the treatment of work at and around expansion joints including, but not limited to, concrete, mechanical, electrical, HVAC, landscaping, masonry, curtain wall, waterproofing, fire-stopping, caulking, flooring and other finish trade subcontractors. All superintendents and foremen with responsibility for oversight and setting of the joint gap must attend this meeting. The General Contractor is responsible to coordinate and schedule all trades and ensure that all subcontractors understand their responsibilities in relation to expansion joints and that their work cannot impede anticipated structural movement at the expansion joints, or compromise the achievement of watertightness or life safety at expansion joints in any way.

- B. Warranty – Manufacturer’s standard warranty shall apply. C.

LEED Building Performance Requirements:

- 1) The VOC of the silicone must not exceed 40 grams/liter
- 2) All substitute products must be proved to be certified by independent test report to exceed the requirements of curtain wall performance tests ASTM E330, E283-04, and E331. Product must meet or exceed hurricane-force wind loading with no deflection at both positive and negative pressures up to 4954 Pascals—equal to 200 mph winds (ASTM E330-02-procedure A).
- 3) Products must be proved to have been certified by independent test report in accordance with ASTM C518-04 and demonstrate an R-Value per 1-inch (25mm) of depth of not less than 2.15 at as-installed nominal joint size compression.
- 4) Products must be proved to have been certified by independent test report to ASTM E-90-09 and to meet or exceed a STC rating of 52 and OITC rating of 38.
- 5) Product must be proved by independent test report to have air permeability not to exceed 0.02 L/(s.m²) at 75 Pascals as required by the Air Barrier Association of America (ABAA) and conform to ASTM E283-04.

PART 2 – PRODUCT

2.01 General

- A. Provide watertight, energy-efficient exterior joints in vertical-plane walls (above-grade). Typical locations include, but are not limited to the following: applications in window perimeters, other façade penetrations such as doors, store fronts, vents, HVAC units, panel to panel joints, curtain walls, control joints, between dissimilar materials, high-movement and seismic structural expansion joints, acoustic partition barriers, and new-to-existing connections.
- B. Provide SEISMIC IBS Series as manufactured by Prospec Specialties Inc. and as indicated on drawings for vertical expansion joint locations.
- C. Preformed sealant shall be silicone pre-coated, preformed, pre-compressed, self-expanding, sealant system. Expanding foam to be cellular foam impregnated with a water-based, non-drying, 100% acrylic dispersion. Seal shall combine factory-applied, low-modulus silicone and a backing of

acrylic-impregnated expanding foam into a unified hybrid sealant system.

- D. Material shall be capable of movements of +50%, -50% (100% total) of nominal material size
- E. Silicone external color facing to be factory-applied to the foam while it is partially pre-compressed to a width greater than maximum joint extension and cured before final compression. When compressed to final supplied dimension, a bellow(s) to handle movement must be created in the silicone coating. Silicone coating to be available in a range of not less than 26 standard colors for coordination with typical building materials.
- F. Select the sealant system model appropriate to the movement and design requirements at each joint location that meet the project specification or as defined by the structural engineer of record.
- G. Manufacturer's Checklist must be completed by expansion joint subcontractor and returned to manufacturer at time of ordering material.

2.02 Fabrication

- A. SEISMIC IBS Series by Prospec Specialties Inc. must be supplied precompressed to less than the joint size, packaged in shrink-wrapped lengths (sticks) with a mounting adhesive on one face.
- B. Directional changes and terminations into horizontal plane surfaces to be provided by factory-manufactured universal-90-degree single units containing minimum 12-inch long leg and 6-inch long leg or custom leg on each side of the direction change or through field fabrication in strict accordance with installation instructions.

PART 3 – EXECUTION

3.01 Installation

A. Preparation of the Work Area

1. The contractor shall provide a properly formed and prepared expansion joint openings constructed to the exact dimensions and elevations shown on manufacturer's standard system drawings or as shown on the contract drawings. Deviations from these dimensions will not be allowed without the written consent of the engineer of record.
2. The contractor shall clean the joint opening of all contaminants immediately prior to installation of expansion joint system. Repair spalled, irregular or unsound joint surfaces using accepted industry practices for repair of the substrates in question. Remove protruding roughness to ensure joint sides are smooth. Ensure that there is sufficient depth to receive the full depth of the size of the SEISMIC IBS Series being installed plus at least ¼-inch (6mm) for the application of corner beads. Refer to Manufacturers Installation Guide for detailed step-by-step instructions.
3. No drilling, or screwing, or fasteners of any type are permitted to anchor the sealant system into the substrate.

3.02 Clean and Protect

- A. Protect the system and its components during construction. Subsequent damage to the expansion joint system will be repaired at the general contractor's expense. After work is complete, clean exposed surfaces with a suitable cleaner that will not harm or attack the finish.